Bureau of Fire Prevention Fire Marshal Roy Mondi

Fire Inspector Ryan Pinnella **Brett Colavito**



Township of Montgomery 100 Community Dr. Skillman, NJ 08558 Phone: 908-359-8211

Fax: 908-533-9329

fireprevention@montgomerynj.gov www.montgomerynj.gov

Exit Sign & Emergency Light Log

Business Name:	
Business Location: _	

60 Minute Annual & 30 Second Monthly Test											
Device ID#	Type of Device E = Exit EL = Emergency Light Combo = Exit & Emergency Light	<u>Location</u>	Person Performing Test	Test Date	$\frac{\text{Type of Test}}{A = \text{Annual}}$ $M = \text{Monthly}$	Result P = Pass F = Fail	<u>Date</u> Repaired	Type of Repair 1 = Battery Replaced 2 = Bulb Replaced 3 = Unit Replaced 4 = Other (explain)	Person Verifying Repair Has Been Made		
2	Е	Rear Exit – Door #2			M	2	3/6/16	1	Jane Doe		

N.J.A.C 5:70-3, 604.3.1.1 Testing. Required emergency lighting systems, including exit signs, shall be tested for proper operation for a minimum of 30 seconds every month. An annual test shall be conducted for at least 1 hour. Equipment shall function properly for the duration of these tests.

Updated: 4/28/23